

Certificate of Product Approval

Certificate Number: 734a

Issue: 02

Eversafe Extinguisher Sdn. Bhd.

Lot 878
 Jalan Subang 9
 Taman Perindustrian Subang
 47500 Subang Jaya
 Selangor Darul Ehsan
 Malaysia

is authorised to use the LPCB mark in association with the product(s) listed in this certificate and appendix having complied with the requirements of the standard(s) detailed below:

Products

EVERSAFE Fire Hose Reels

FireSafe Fire Hose Reels

Red Panther Fire Hose Reels

Standards

EN 671-1:2012

Fixed firefighting systems. Hose systems. Hose reels with semi-rigid hose

This certificate and appendix is maintained and held in force through regular surveillance activities



Signed for LPCB

Joe Milton

Verifier

27 January 2015

Date of Issue

20 February 2012

Date of First Issue



This certificate and appendix remain the property of BRE Global Ltd and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

LPCB is part of BRE Global Ltd, Garston, Watford, WD25 9XX
 T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: enquiries@breglobal.com




Appendix to Certificate No: 734a Eversafe Extinguisher Sdn. Bhd.

Issue: 02

Fire Hose Reels to EN 671-1:2012

Product Name	Description	Hose Nominal Bore (mm)	Hose Maximum Length (m)	Nozzle type	LPCB Ref. No.
EE-CSJR-08	Manual, swinging arm, cabinet or wall mounted	19	30	Lever operated jet only or rotary operated jet/spray	734a/01
EE-CSJR-07	Manual, swinging arm, cabinet or wall mounted	25	30	Lever operated jet only or rotary operated jet/spray	734a/02
EE-CSJR-10	Automatic, swinging arm, cabinet or wall mounted	19	30	Lever operated jet only or rotary operated jet/spray	734a/03
EE-CSJR-06	Automatic, swinging arm, cabinet or wall mounted	25	30	Lever operated jet only or rotary operated jet/spray	734a/04
EE-CSJR-01	Manual, swinging arm, wall mounted	33	30	Rotary operated jet/spray	734a/05
FS-CSJR-08	Manual, swinging arm, cabinet or wall mounted	19	30	Lever operated jet only or rotary operated jet/spray	734a/06
FS-CSJR-07	Manual, swinging arm, cabinet or wall mounted	25	30	Lever operated jet only or rotary operated jet/spray	734a/07
FS-CSJR-10	Automatic, swinging arm, cabinet or wall mounted	19	30	Lever operated jet only or rotary operated jet/spray	734a/08
FS-CSJR-06	Automatic, swinging arm, cabinet or wall mounted	25	30	Lever operated jet only or rotary operated jet/spray	734a/09
FS-CSJR-01	Manual, swinging arm, wall mounted	33	30	Rotary operated jet/spray	734a/10

This certificate and appendix is maintained and held in force through regular surveillance activities

J. Mit.

Signed for LPCB

Joe Milton
Verifier

27 January 2015
Date of Issue

20 February 2012
Date of First Issue



This certificate and appendix remain the property of BRE Global Ltd and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR Tag or contact us.

LPCB is part of BRE Global Ltd., Garston, Watford WD25 9XX.

T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: Enquiries@breglobal.com



bre

Appendix to Certificate No: 734a Eversafe Extinguisher Sdn. Bhd.

Issue: 02

Fire Hose Reels to EN 671-1:2012

Product Name	Description	Hose Nominal Bore (mm)	Hose Maximum Length (m)	Nozzle type	LPCB Ref. No.
RP-CSJR-08	Manual, swinging arm, cabinet or wall mounted	19	30	Lever operated jet only or rotary operated jet/spray	734a/11
RP-CSJR-07	Manual, swinging arm, cabinet or wall mounted	25	30	Lever operated jet only or rotary operated jet/spray	734a/12
RP-CSJR-10	Automatic, swinging arm, cabinet or wall mounted	19	30	Lever operated jet only or rotary operated jet/spray	734a/13
RP-CSJR-06	Automatic, swinging arm, cabinet or wall mounted	25	30	Lever operated jet only or rotary operated jet/spray	734a/14
RP-CSJR-01	Manual, swinging arm, wall mounted	33	30	Rotary operated jet/spray	734a/15

Notes:

- 1) EE prefix are branded "EVERSAFE"
- 2) FS prefix are branded "FireSafe"
- 3) RP prefix are branded "Red Panther"

This certificate and appendix is maintained and held in force through regular surveillance activities

J. Mit.

Signed for LPCB

Joe Milton
Verifier

27 January 2015
Date of Issue

20 February 2012
Date of First Issue



This certificate and appendix remain the property of BRE Global Ltd and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR Tag or contact us.

LPCB is part of BRE Global Ltd., Garston, Watford WD25 9XX.

T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: Enquiries@breglobal.com



bre